

WELL CONSTRUCTOR'S REPORT

Well-6

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1 COUNTY	Ozaukee	CHECK ONE	NAME
		<input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City	Cedarburg

2 LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available)
--

NW 1/4 of SE 1/4 of Sec. 35 T 10 NR 21 E

3. OWNER AT TIME OF DRILLING

Edward Kelln

4. OWNER'S COMPLETE MAIL ADDRESS

121 East Wurthmann Street Cedarburg, Wisconsin 53012

5. Distance in feet from well to nearest:	BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
(Record answer in appropriate block)	C. I.	TILE	C. I.	SEWER CONNECTED	INDEPENDENT

14

14

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I.	TILE							

70

75

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for:

House

7. DRILLHOLE	10. FORMATIONS
--------------	----------------

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	45	6	45	153	Clay	Surface	30
						Limestone	30	153

8. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	19.45# new bl. steel	Surface	45
	T&C well case.		

9. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Cement slurry	Surface	45

11. MISCELLANEOUS DATA

Yield test:	10	Hrs. at	12	GPM	Well construction completed on	Sept. 2	1969
Depth from surface to normal water level	25	ft.	Well is terminated	10	inches	<input checked="" type="checkbox"/> above <input type="checkbox"/> below	final grade
Depth to water level when pumping	50	ft.	Well disinfected upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Well sealed watertight upon completion	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

Water sample sent to	Madison	laboratory on:	Sept. 2,	1969
----------------------	---------	----------------	----------	------

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE	COMPLETE MAIL ADDRESS
-----------	-----------------------

Registered Well Driller	53012
631 South Washington Ave., Cedarburg, Wis.	

Please do not write in space below

GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
---------------	---------------	-----------	---------